

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
12/6/01	12/6/01	21380	Contractor	Rialto Wastewater Treatment Plant. Rialto, San Bernardino County	SSO	80,000	An estimated 80,000 gallons of the Dynasand filter reject water was released into the treatment facility's storm drain system which feeds to the dry-pit onsite for containment. All of the spill was contained and diverted to the headworks. The release of the effluent was due to equipment failure. The equipment was repaired, and the affected area was cleaned up and disinfected by OMI staff.
12/16/01	12/16/01	21343	City of San Bernardino	592 Middle Fork Rd., San Bernardino, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to a large wooden stick dropped into the manhole by vandals. None of the spill was contained and it discharged on to an open field where it percolated. The wooden stick was removed; the affected area was cleaned up, and disinfected by City of San Bernardino staff.
12/28/01	12/28/01	21775	San Bernardino Water Department	399 Chandler Place, San Bernardino, San Bernardino County	SSO	60,000	An estimated 60,000 gallons of sewage discharged from a digester due to power failure. All 60,000 gallons of the spill were contained on-site, recovered, and returned to the headworks of the plant. The failed equipment was repaired and the affected area was cleaned up and disinfected by San Bernardino Water Department staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
1/8/02	1/8/02	22089	Jurupa Community Services District	2115 Roimer Dr & Sunnyslope, Riverside, Riverside County	SSO	1,100	An estimated 1,100 gallons of sewage overflowed from a manhole due to unspecified reasons. All 1,100 gallons of the spill were contained, recovered and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up and disinfected by Jurupa Community Services District staff.
1/12/02	1/12/02	22492	City of Santa Ana	1st St & Mountain View, Santa Ana, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to a grease blockage. All 1,000 gallons of sewage discharged into a nearby storm drain. The blockage was cleared and the affected area cleaned up by City of Santa Ana staff.
1/15/02	1/15/02	22434	Eastern Municipal Water District	End of Postal Ave, Moreno Valley, Riverside County	SSO	57,000	An estimated 57,000 gallons of sewage overflowed from a manhole due to debris blockage caused by vandalism. Approximately 56,000 gallons of the spill were contained, recovered and returned to the operational sewer system, while the rest of the spill discharged into a local storm channel. The blockage was cleared; and the affected area was cleaned up and disinfected by Eastern Municipal Water District staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
1/16/02	1/16/02	23021	Irvine Ranch Water District	Campobello & Ridge Park, Newport Beach, Orange County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to blockage caused by construction debris. Approximately 130 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a nearby storm drain. The blockage was cleared; and the affected area was cleaned up and disinfected by City of Newport Beach staff.
1/24/02	1/23/02	22436	City of Ontario	951 North Milliken Ave, Ontario, San Bernardino County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a manhole due to unspecified circumstances. All 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Ontario Staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
1/27/02	1/27/02	22488	Private Property Owner	7378 E Singing Wood Drive, Anaheim, Orange County	SSO	1,200	An estimated 1,200 gallons of sewage overflowed from a private lateral due to root blockage. Approximately 940 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a nearby storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Anaheim staff.
1/28/02	1/28/02	22435	Rancho Cucamonga Water District	North East Corner of Beryl and Highland, Rancho Cucamonga, San Bernardino County	SSO	5,000	An estimated 5,000 gallons of sewage was released from a broken 8" sewer line due to rain water damage. All 5,000 gallons of the spill discharged into a local storm drain. The sewage flow was diverted to another section of sewer system to avoid further spills. The affected area was cleaned up, and the broken sections of sewer system will be repaired and put into operation by Cucamonga Water District staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
1/29/02	1/29/02	22507	Private Property Owner	400 West Orangethorpe, Fullerton, Orange County	SSO	---	An unknown amount of sewage overflowed from a private lateral due to unknown blockage. All of the spill was discharged into the sub-basement of an apartment complex. Approximately 20 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area was cleaned up and disinfected by the Private Property Owner.
2/1/02	2/1/02	23016	Orange County Sanitation District	Jamboree & Edinger, Irvine, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to unknown blockage. 300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by Orange County Sanitation District staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/1/02	2/1/02	23301	Private Property Owner	2953 Edinger Ave, Tustin, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to a blockage caused by construction debris. 300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by a Private Property Owner.
2/1/02	2/1/02	23216	Pelican Hills Golf Club	Pelican Hills Golf Club, Newport Beach, Orange County	TRW	15,000	An estimated 15,000 gallons of tertiary reclaimed water (TRW) was released from a broken sprinkler valve. None of the spill was recovered and it discharged into a local storm drain and flowed to Newport Bay. The broken valve was repaired and the affected area was cleaned up by Pelican Hills Golf Club staff.
2/1/02	2/1/02	23072	City of Beaumont	Euclid Ave & Elm Ave, Beaumont, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to unknown blockage. Approximately 500 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged to an open field and percolated. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Beaumont staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/2/02	2/2/02	23020	City of Garden Grove	12231 Sheridan Ln, Garden Grove, Orange County	SSO	750	An estimated 750 gallons of sewage overflowed from a manhole due to grease blockage. All 750 gallons of sewage were contained, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Garden Grove staff.
2/4/02	2/4/02	23071	Private Property Owner	14928 Springdale Ave, Huntington Beach, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a private lateral due to a grease blockage. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by a Private contractor with the assistance of City of Huntington Beach staff.
2/4/02	2/4/02	23224	Pelican Hills Golf Club	Pelican Hills Golf Club, Newport Beach, Orange County	TRW	25,000	An estimated 25,000 gallons of tertiary recycled water (TRW) was released from a broken sprinkler valve. All 25,000 gallons of the spill discharged into a local storm drain and flowed to Newport Bay. The broken valve was repaired, and the affected area was cleaned up by Pelican Hills Golf Club staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/5/02	2/5/02	23222	City of Perris	Perris Blvd between 6th & 7th, Perris, Riverside County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to a grease blockage. All 900 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Perris staff.
2/5/02	2/5/02	23300	City of Placentia	Bradford & Carlson, Placentia, Orange County	SSO	1,200	An estimated 1,200 gallons of sewage overflowed from a manhole due to an unknown blockage. Approximately 900 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Placentia staff.
2/7/02	2/7/02	23221	City of Riverside	La Sierra & Blue Jay, Riverside, Riverside County	SSO	1,455	An estimated 1,455 gallons of sewage overflowed from a manhole due to debris blockage. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Riverside staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/9/02	2/9/02	23219	City of Stanton	Western & Cerritos, Stanton, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to blockage caused by cloth rags. Approximately 300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill was discharged into a local storm drain. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Stanton staff.
2/13/02	2/13/02	23218	Irvine Ranch Water District	Serrano Creek Construction Project, Lake Forest, Orange County	SSO	11,260	An estimated 11,260 gallons of sewage overflowed from a sewer line break caused by construction. Approximately 10,300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into an excavated soil field where it percolated. The broken sewer line was repaired, and the affected area was cleaned up by Irvine Ranch Water District.